

CHRIS MINNICH
H. YOUNG - 10/29 (11)

(FRED FIFE)

SEPTIC TANK DOES NOT FUNCTION BECAUSE WATER FROM WILSON IRRIGATION DITCH SIPHON MAY BE THE REASON THAT DRAINAGE DOES NOT FUNCTION - STANDING WATER IN A DUG HOLE INDICATES A BLOCKAGE ALONG NORTH SIDE OF 1800 SOUTH, IN FIFE LAWN AREA.

IRRIGATION DITCHES IN AREA MAY CONTRIBUTE TO THE PRESENT PROBLEM.

MR WENDELL HOLMES, PRESIDENT WILSON IRRIGATION DISTRICT WAS CONTACTED BY FRED FIFE REPORTING HIS DRAINAGE PROBLEM.

ASSESSMENT OF SITUATION:

LOW GROUND AND SITE ELEV - REQUIRES PUMPING OF EFFLUENT THRU A CLOSED SEWAGE SYSTEM. (See NIELSON & MAXWELL