

June 20th 1899 50

✓ Sewer Connection made by John White
for James Macth. on 23rd Street
for J.C. Armstrong, Intersects Property
line 15 feet east of 1st Station.

Call O.K. Water and Sewer
made it found work - -
#

June 27th 1899

✓ Notified Steam Laundry that
flush pipe to Closet was not
properly connected to Siphon
and that it would not be accepted
by the Truck Plumber

Recd Hotel Co Owners.
A. F. Parker City Eng. p. H. H. Seymour
Inspector.

#

Inspection Sewer Connection
Thomas Whelan made O.K.
Intersects property line 10 feet east of
1st Station Nos 344 & 346 24th St.
John White Drain Sayer

#

Inspection Sewer Connection about
330 O.K. Intersects property line 11 feet
east of 1st Station John White Drain Sayer
#