

Main hall at 26th and wall in fair
condition. About 2 1/2 in water, tile dry

1st ps. ys. O.K.

2 ps. ys. O.K.

3rd ps. ys. O.K.

4th ps. ys. O.K. 3ft north leak in bottom

5th ps. ys. O.K. About 2ft north small stream
commencing in an west side

6th ps. ys. O.K.

7th ps. ys. O.K.

8th ps. ys., leaking some around outside

9th ps. ys., west one leaking some.

10th ps. ys. leaks around the outside. some

11th ps. ys. O.K.

12th ps. ys. O.K.

13th ps. ys. east one leaks around the y.

14th ps. ys. O.K.

Main hall Bt. 26th & 28th on wall
fair condition. Tile dry.

1st ps. ys. O.K.

2nd ps. ys. O.K.

3rd ps. ys., west one O.K., east one dripping
under the y.

4th ps. ys. O.K.

5th ps. ys. O.K. About 1ft south small leak
on the side

6th ps. ys. O.K.

7th ps. ys. O.K.

8th ps. ys., east one leaking around y.

9th ps. ys., east one leaking around y

10th ps. ys. O.K.

11th ps. ys. O.K.

12th ps. ys. O.K.

13th ps. ys. O.K.

14th ps. ys. O.K.

15th ps. ys. O.K.